

Last update: April 2018

## Machinery Directive 2006/42/EC

*ASERCOM*, the Association of European Refrigeration Component Manufacturers, has examined the implications of the revised Machinery Directive 2006/42/EC (MD) regarding compressors and condensing units produced by *ASERCOM* members.

After evaluation of this directive and applying the guideline published by the European Commission\* with respect to its application to refrigeration compressors and condensing units, *ASERCOM* has adopted the following position in agreement with European legislation and practice:

- Refrigerant Compressors and Condensing Units are subjected to the Machinery Directive because they are considered “Partly Completed Machinery” in the sense of the MD
- *ASERCOM* members are complying with the requirements of documentation for partly completed machinery as laid down in the MD
  - Documents to be provided with each individual product sold
  - Language requirements to provide information to the end-user
  - Individually adjusted scope of documents provided per mutual agreement between supplier and customer
- A “Declaration of Incorporation” is provided by the manufacturer as required by the MD for Partly Completed Machinery whereas a “Declaration of Conformity” must not be issued
- Likewise a CE mark with reference to the Machinery Directive will not be attached to the products, BUT
  - Other Directives may make it necessary to affix a CE mark to the product
  - Compliance statements with respect to these directives have to be provided
  - ⊖ Products excluded from the scope of Machinery Directive, as they are used as electrical and electronic products in the scope of Low Voltage Directive such as motor compressors for household and similar electrical appliances will have a CE mark and have the corresponding declaration of conformity.

\*Guide to application of the Machinery Directive 2006/42/EC  
Edition 2.1 – July 2017  
(Update of 2nd Edition)  
European Commission, DG Enterprise and Industry

---

These recommendations are addressed to professionals, industrial, commercial and domestic refrigeration system manufacturers / installers. They have been drafted on the basis of what *ASERCOM* believes to be the state of scientific and technical knowledge at the time of drafting, however, *ASERCOM* and its member companies cannot accept any responsibility for and, in particular, cannot assume any reliability with respect to any measures - acts or omissions - taken on the basis of these recommendations.

---