## **STATEMENT**

Last update: May-2011



## Carbon Dioxide (CO2) in Refrigeration and Air-Conditioning Systems (RAC)

Carbon dioxide  $(CO_2)^1$  was one of the first refrigerants to replace early air cycle systems and was in use primarily for shipboard refrigeration in the beginning of the twentieth century. It was then superseded by chlorofluorocarbons. However, since  $CO_2$  is environmentally benign, non-toxic (in the classical sense), non-flammable, chemically inactive and offers a very high volumetric cooling capacity together with excellent heat transfer properties, it is increasingly considered for use today in RAC systems. Because of its very low global warming potential and zero  $ODP^2$ ,  $CO_2$  systems do not need the very stringent containment criteria necessary for HFCs and other refrigerants. Since  $CO_2$  is in the same safety class (A1) as HFCs the safety requirements may be less onerous than they would be for ammonia or hydrocarbons.

The thermodynamic characteristics of  $CO_2$  are very different to the refrigerants usually applied in RAC systems. Its very low critical temperature of 31°C may require trans-critical operation, depending on the heat sink temperature on the discharge side. The energy efficiency tends to be lower as compared to a sub-critical conventional system and the system design for trans-critical operation will differ from a conventional vapour compression cycle. Nevertheless, in the right circumstances  $CO_2$  systems can reach or exceed the energy efficiency of systems with established refrigerants.

Pressure levels and volumetric cooling capacity for  $CO_2$  systems are much higher than those for conventional systems. This results in smaller compressor displacement and smaller tube dimensions, and many components, particularly the compressors, need to be specifically designed for use with  $CO_2$ .

Therefore,  $CO_2$  technology cannot be seen as a general alternative solution to systems with HFCs,  $NH_3$  or hydrocarbons and in no circumstances must  $CO_2$  be introduced into a non- $CO_2$  system. Any development/application of  $CO_2$  RAC systems requires a careful assessment of system efficiency,  $TEWI^3$ , life cycle cost, technical feasibility, reliability and safety aspects.

ASERCOM members are involved in projects with  $CO_2$  as a refrigerant. Components and solutions for its application have started to become available. However, before proceeding with a  $CO_2$  application, individual consultation with manufacturers is required due to the very specific issues involved.

These recommendations are addressed to professionals, industrial, commercial and domestic refrigeration system manufacturers / installers. They have been drafted on the basis of what *ASERCOM* believes to be the state of scientific and technical knowledge at the time of drafting, however, *ASERCOM* and its member companies cannot accept any responsibility for and, in particular, cannot assume any reliability with respect to any measures - acts or omissions - taken on the basis of these recommendations.

<sup>&</sup>lt;sup>1</sup> R744 according to ISO 817 / EN378-1

<sup>&</sup>lt;sup>2</sup> ODP Ozone Depleting Potential

<sup>&</sup>lt;sup>3</sup> TEWI Total Equivalent Warming Impact